

Doña Ana Mutual Domestic Water Consumers Association NM3554307 2019 Consumer Confidence Report

Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 12 of those contaminants, and found only 1 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Doña Ana MDWCA's water source comes from productive wells, which draw ground water from the Mesilla Bolson.

Source water assessment and its availability

All information concerning water quality for Doña Ana MDWCA's members can be found on our website, www.dawater.org, and our information board outside of our office located at 5535 Ledesma Dr. Las Cruces NM 88007 or call 575-526-3491.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

You can become more involved by attending the Regular Board Meeting on the 1st and 3rd Thursdays of every month at 0900 hrs. (Unless the office is closed for Holidays) A calendar of said meetings and office closures is available at any time during business hours with our friendly clerks at the front desk at our office at 5535 Ledesma Dr. Las Cruces NM 88007 or call us at 575-526-3491.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Monitoring and reporting of compliance data violations

Monitoring Requirements Not Met for Dona Ana MDWCA

On 9/24/2016, we became aware that our system recently failed to collect monitoring samples required by the Stage 2 Disinfectants/Disinfection Byproducts Rule. Although this incident was not an emergency, as our customers, you have the right to know that happened, and what we are doing to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Below list the contaminants and the compliance periods for which we did not monitor correctly. Because these samples were not collected, we cannot be sure of the quality of our drinking water during the compliance periods listed below.

Total Trihalomethanes and Haloacetic Acids, TTHM - 1 1110 Burke Rd, Quarterly, 4th Quarter 2013, 2nd and 3rd Quarters 2014

Total Trihalomethanes and Haloacetic Acids, TTHM - 2 5535 Ledesma Rd, Quarterly, 4th Quarter 2013, 2nd and 3rd Quarters 2014

Total Trihalomethanes and Haloacetic Acids, HAAS - 1 2601 Dona Ana Rd, Quarterly, 4th Quarter 2013, 2nd and 3rd Quarters 2014

Total Trihalomethanes and Haloacetic Acids, DBP - 1 12695 Leasburg SP Rd, Quarterly, 4th Quarter 2013, 2nd and 3rd Quarters 2014

What should you do?

There is nothing you need to do. You do not need to boil your water or take other corrective actions. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What happened and what is being done?

The corrective steps have been taken by collecting the Haloacetic Acids (HAA5) and the Total Trihalomethanes (TTHM) samples during the 4th quarter 2018.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Doña Ana Mutual Domestic Water Consumers Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Lead and copper analysis is conducted every three years as mandated by New Mexico State law and EPA standards. Doña Ana MDWCA systems are due for testing July 2018.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	.3	.3	.3	2019	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	6	0	8.6	2019	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	45	0	54	2019	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	.044	.044	.044	2019	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	.9	.9	.9	2019	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	1	0	.82	2019	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	2	2	2	2019	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	9.7	.5	9.7	2019	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	1.5	.35	1.5	2019	No	Erosion of natural deposits
Uranium (ug/L)	0	30	33	2	33	2019	Yes	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.29	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Lead - action level at consumer taps (ppb)	0	15	2.5	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Violations and Exceedances
<p>Uranium</p> <p>Some people who drink water containing uranium in excess of the MCL (30 ug/L) over many years may have increased risk of getting cancer and kidney toxicity. The violation occurred on January 15, 2019. The violation is at the West Mesa Storage Tank #2. The tank is no longer in use as of January 2019. The violation has been corrected by taking the West Mesa Storage Tanks off line from the system. Currently the West Mesa area is provided water from Well #7, Well #16, and the three storage tanks located in Picacho Hills.</p>

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Important Drinking Water Definitions	
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

TT Violation	Explanation	Length	Health Effects Language	Explanation and Comment
Ground Water Rule violations	Ground Water Rule - The Ground Water Rule specifies the appropriate use of disinfection while addressing other components of ground water systems to ensure public health protection. The system Failed to Address Deficiency (GWR).	The length of the violation was from 10/12/2016 to 09/30/2018.	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.	The corrective steps have been taken by submitting the required documentation to compliance monitor and the violation ended in 2018.

For more information please contact:

Contact Name: Jennifer Horton
Address: 5535 Ledesma Dr.
Las Cruces, NM 88007
Phone: 575-526-3491

Community Water System Name: _____

Water System Identification Number: _____

Calendar Year of Report: 2019

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency.

Certified By (Name): _____

Title: _____

Phone # _____ Date of this Certification: _____

Check all applicable methods of delivery and provide the date each was completed. Forms that do not include the date of delivery for each method used may be rejected.

METHOD OF DELIVERY

DATE OF DELIVERY

CCR was distributed by mail or other direct delivery. _____

The following are "Good faith" efforts that may be used to reach non-bill paying consumers:

Posted the CCR on the Internet at www. _____

Mailed to each bill-paying customer a notification that the CCR is available on the Internet at _____

E-mailed to each bill-paying customer a notification that the CCR is available on the Internet at: _____

E-mailed the CCR as an electronic file email attachment _____

Mailed the CCR to postal patrons within the service area. (**attach zip codes used**) _____

Advertised availability of the CCR in news media (**attach copy of announcement**) _____

Publication of the CCR in local newspaper (**attach copy**) _____

Posted the CCR in public places (**attach a list of locations**) _____

Delivery of multiple copies to single bill addresses serving several persons such as apartments, businesses, and large private employers _____

Delivery to community organizations (**attach a list**) _____

(For systems serving at least 100,000 persons) Posted CCR on a publicly-accessible internet _____

Delivered CCR to other agencies/water systems as required by the primacy agency (**attach a list**) _____